



**CERTIFICAT DE CALITATE PRODUS FINIT**  
**СЕРТИФИКАТ КАЧЕСТВА**  
№ 2264

COD: CC-PF-001  
EDITIA: 1  
REVIZIA: 0  
DATA: 15.01.2020.

- 1 DATA: 02.06.2021  
2 DENUMIRE PRODUS FINIT: Plasa din fibre de sticla: 110  
3 DATA PRODUCERE: 01.06.2021  
4 TERMEN PASTRARE: 2 ani din data producerii

No	Indicator	Un.m	Norma	Rez.testelor	ACTE normative
1	Numarul de fire la 10 cm (directia longitudinala)	10 cm	38-42	41	EAD 040016-00-0404:2016, Cl. 2.2.6
2	Numarul de fire la 10 cm (directia transversala)	10 cm	15-19	19	EAD 040016-00-0404:2016, Cl. 2.2.6
3	Latime	cm	99,5-101	100	EAD 040016-00-0404:2016, Cl. 2.2.5
4	Greutate la 1 unitate de suprafata	g/m <sup>2</sup>	105-115	108,5	EAD 040016-00-0404:2016, Cl. 2.2.8
5	Pierderi la calcinare	%	≥ 10	10,8	EAD 040016-00-0404:2016, Cl. 2.2.2
6	Sarcina la rupere (directia longitudinala)	N/ 5 cm	≥ 1000	1 708	u\o 040016-00-0404:2016, Cl. 2.2.7
7	Sarcina la rupere (directia transversala)	N/5 cm	≥ 1000	2 626	u\o 040016-00-0404:2016, Cl. 2.2.7
8	Sarcina la rupere (directia longitudinala 28 zile)	N/50 mm	≥ 500	854	u\o 040016-00-0404:2016, Cl. 2.2.7
9	Sarcina la rupere (directia transversala 28 zile)	N/50 mm	≥ 500	750	u\o 040016-00-0404:2016, Cl. 2.2.7
10	Dimensiunea celulei in directie longitudinala	mm	≥ 3	4,9	EAD 040016-00-0404:2016, Cl. 2.2.4
11	Dimensiunea celulei in directie transversala	mm	≥ 3	5,3	EAD 040016-00-0404:2016, Cl. 2.2.4

Director de Producere \_\_\_\_\_

